



Phone (608) 269-3752
FAX (608) 269-8129
(800) 533-0551

P.O. Box 172 • 930 Roberts Road • Sparta, WI 54656

INSTRUCTIONS GROUND FAULT CIRCUIT INTERRUPTER (GFCI)

CAUTION: DO NOT USE EXTENSION CORD TO CONNECT THIS DEVICE TO POWER RECEPTACLE.

WARNING: TEST BEFORE EACH USE

- 1) INSERT THE GFCI PLUG INTO A GROUNDED 120 VAC RECEPTACLE.
- 2) WHEN TEST BUTTON IS PUSHED IN THE RED INDICATOR LIGHT SHOULD GO OFF.
- 3) PUSH THE RESET BUTTON IN, IF THE RED INDICATOR LIGHT IS ON THE MACHINE IS READY FOR USE.
- 4) DO NOT USE THE MACHINE IF THE LIGHT DOES NOT GO ON WHEN RESET.
- 5) DO NOT USE THE MACHINE IF THE INDICATOR LIGHT REMAINS ON WHEN THE TEST BUTTON IS PUSHED.
- 6) THIS GFCI OFFERS NO PROTECTION FROM CONTACT WITH BOTH CIRCUIT CONDUCTORS.
- 7) THIS GFCI OFFERS NO PROTECTION AGAINST ELECTRICAL SHOCK RESULTING FROM DEFECTS OR FAULTS IN ANY WIRING SUPPLYING POWER TO THIS UNIT.

ADDITIONAL INFORMATION ON BACK OF GFCI